

- 1. Read the *IAQ*Backgrounder and the Background Information for this checklist.
- 2. Keep the
 Background
 Information and
 make a copy of
 the checklist for
 future reference.
- 3. Complete the Checklist.
 - Check the "yes,"
 "no," or
 "not applicable"
 box beside each
 item. (A "no"
 response requires
 further attention.)
 - Make comments in the "Notes" section as necessary.
- Return the checklist portion of this document to the IAQ Coordinator.

Building and Grounds Maintenance Checklist

Lory kneeland
i was
Date Completed: 12105 2024
rako

1.	BUILDING MAINTENANCE SUPPLIES	Voc	No	N/A
la.	Developed appropriate procedures and stocked supplies for spill control			
	Reviewed supply labels	X		
1c.	Ensured that air from chemical and trash storage areas vents to	(C)		
1d	the outdoors	R		
		ĬQ.		
1e.	containers	X		
1 f.		·		
1α	Ensured that chemicals, chemical-containing wastes, and containers are	P		
ıg.	disposed of according to manufacturers' instructions	(20		
1h.	Substituted less- or non-hazardous materials (where possible)			
1 i.	Scheduled work involving odorous or hazardous chemicals for periods	1	_	
1j.	when the school is unoccupied	A.		
1).	hazardous chemicals	X		
		Ш		
2.	GROUNDS MAINTENANCE SUPPLIES			
	Stored grounds maintenance supplies in appropriate area(s)	. ¤		
2b.	Ensured that supplies are used and stored according to manufacturers'	Not		
20	instructions Established and followed procedures to minimize exposure to fumes	.29		
20.	from supplies	(X.		
2d.	Reviewed and followed manufacturers' guidelines for maintenance			
	Replaced portable gas cans with low-emission cans	· 7		
2f.	The state of the s			
2g.		×		
-5.	disposed of according to manufacturers' instructions	W.		
3.				
3a.	Installed and maintained barrier mats for entrances	₽.		
3b.	Used high efficiency vacuum bags	2		
3c.	Used proper dusting techniques	K		
3a.	wrapped reather dusters with a dust cloth	. ہمر .		_

4.	FLOOR CLEANING	es	No	N/A	
4b.	Established and followed schedule for vacuuming and mopping floors	≱	0 0	0	
5 .	DRAIN TRAPS				
5b.	Poured water down floor drains once per week (about 1 quart of water)	, S	0 0	0	
6.	MOISTURE, LEAKS, AND SPILLS				
6 a . 6 b .	Checked for moldy odors	Ą			
60	indicate periodic leaks)	9			
	locker rooms, and bathrooms)	×(0		
	condensate	Ą			
	Checked that indoor surfaces of exterior walls and cold water pipes are free of condensate	ð	۵		
61.	Ensured the following areas are free from signs of leaks and water damage: Indoor areas near known roof or wall leaks Walls around leaky or broken windows Floors and ceilings under plumbing Duct interiors near humidifiers, cooling coils, and outdoor air intakes	के ब		0	
7.	COMBUSTION APPLIANCES				
7b. 7c.	Checked for odors from combustion appliances	4		0 0 0	
8.	PEST CONTROL				
8a.	Completed the Integrated Pest Management Checklist	K			





- Read the IAQ
 Backgrounder and the Background Information for this checklist.
- 2. Keep the
 Background
 Information and
 make a copy of
 this checklist for
 each ventilation
 unit in your school,
 as well as a
 copy for future
 reference.
- 3. Complete the Checklist.
 - Check the "yes,"
 "no," or
 "not applicable"
 box beside each
 item. (A "no"
 response
 requires further
 attention.)
 - Make comments in the "Notes" section as necessary.
- Return the checklist portion of this document to the IAQ Coordinator.

Ventilation Checklist

Name: Tred Ubst Donna Leake		
School: <u>East-Fard</u> Elementary		
Unit Ventilator/AHU No: Gym AHU office AHU Library A	HU)
Room or Area: Date Completed: 6-23 6- Signature: Signature: Date Completed: 6-23 6-		
3110		
1. OUTDOOR AIR INTAKES		
1a. Marked locations of all outdoor air intakes on a small floor plan (for example, a fire escape floor plan). See a Hacked	No	N/
1b. Ensured that the ventilation system was on and operating in "occupied" mode	۵	
ACTIVITY 1: OBSTRUCTIONS		
1c. Ensured that outdoor air intakes are clear of obstructions, debris, clogs, or covers		
Id. Installed corrective devices as necessary (e.g., if snowdrifts or leaves frequently block an intake)		
ACTIVITY 2: POLLUTANT SOURCES		
1e. Checked ground-level intakes for pollutant sources (dumpsters, loading docks, and bus-idling areas)		
1f. Checked rooftop intakes for pollutant sources (plumbing vents; kitchen, toilet, or laboratory exhaust fans; puddles; and mist from		
lg. Resolved any problems with pollutant sources located near outdoor air		
intakes (e.g., relocated dumpster or extended exhaust pipe)		C
ACTIVITY 3: AIRFLOW		
1h. Obtained chemical smoke (or a small piece of tissue paper or light plastic) 1i. Confirmed that outdoor air is entering the intake appropriately	0	
2. SYSTEM CLEANLINESS		
ACTIVITY 4: AIR FILTERS		
2a. Replaced filters per maintenance schedule2b. Shut off ventilation system fans while replacing filters (prevents dirt from		C
blowing downstream) 2c. Vacuumed filter areas before installing new filters	a	(
2d. Confirmed proper fit of filters to prevent air from bypassing (flowing around) the air filter		
2c. Confirmed proper installation of filters (correct direction for airflow)	0	Ċ

2. SYSTEM CLEANLINESS (continued)

ACTIVITY 5: DRAIN PANS			
2f. Ensured that drain pans slant toward the drain (to prevent water from			N/A
accumulating)	🔀		
2g. Cleaned drain pans			a
2h. Checked drain pans for mold and mildew	M		Q
ACTIVITY 6: COILS			
2i. Ensured that heating and cooling coils are clean	X		a
ACTIVITY 7: AIR-HANDLING UNITS, UNIT VENTILATORS			
2j. Ensured that the interior of air-handling unit(s) or unit ventilator			
(air-mixing chamber and fan blades) is clean	火		
2k. Ensured that ducts are clean	×		
ACTIVITY 8: MECHANICAL ROOMS			
21. Checked mechanical room for unsanitary conditions, leaks, and spills	🔉		
2m. Ensured that mechanical rooms and air-mixing chambers are free of trash,	4		
chemical products, and supplies	,,,,,	a	
3. CONTROLS FOR OUTDOOR AIR SUPPLY			
3a. Ensured that air dampers are at least partially open (minimum position)	. 34		0
3b. Ensured that minimum position provides adequate outdoor air	X22		
for occupants) A(a	
ACTIVITY 9: CONTROLS INFORMATION			
3c. Obtained and reviewed all design inside/outside temperature and humidity			
requirements, controls specifications, as-built mechanical drawings,			
and controls operations manuals (often uniquely designed)	×(u	
ACTIVITY 10: CLOCKS, TIMERS, SWITCHES			
3d. Turned summer-winter switches to the correct position)X(0	0
)24		
3f. Ensured that settings fit the actual schedule of building use (including night/weekend use)	ċΧ		
inglia vocation asset in the same and the same asset in the same as the same a		_	
ACTIVITY 11: CONTROL COMPONENTS			
3g. Ensured appropriate system pressure by testing line pressure at both the	_		λ./
occupied (day) setting and the unoccupied (night) setting			₹
3h. Checked that the line dryer prevents moisture buildup	u		J.
3i. Replaced control system filters at the compressor inlet based on the			
compressor manufacturer's recommendation (for example, when you blow down the tank)	m	0	(X)
3j. Set the line pressure at each thermostat and damper actuator at the proper	🛥	•	×
level (no leakage or obstructions)	ω	a	M
ACTIVITY 12. OUTDOOD AID DAMBERS			•
ACTIVITY 12: OUTDOOR AIR DAMPERS 3k Ensured that the outdoor air damper is visible for inspection	·W		0
3k. Ensured that the outdoor air damper is visible for inspection3l. Ensured that the recirculating relief and/or exhaust dampers are visible	.,/	J	J
for inspection	74		
3m. Ensured that air temperature in the indoor area(s) served by each	/		_
outdoor air damper is within the normal operating range	þ		



NOTE: It is necessary to ensure that the damper is operating properly and within the normal range to continue.



3. CONTROLS FOR OUTDOOR AIR SUPPLY (continued)			
3n. Checked that the outdoor air damper fully closes within a few minutes of shutting off appropriate air handler			N/A
30. Checked that the outdoor air damper opens (at least partially with no delay) when the air handler is turned on	A		
3p. If in heating mode, checked that the outdoor air damper goes to its minimum position (without completely closing) when the room thermostat is set to 85°F.	NOW!	П	0
3q. If in cooling mode, checked that the outdoor air damper goes to its minimum position (without completely closing) when the room thermostat is set	n	_	
to 60°F and mixed air thermostat is set to 45°F	P		
The damper actuator links to the damper shaft, and any linkage set screws or bolts are tight		0	
 Moving parts are free of impediments (e.g., rust, corrosion) Electrical wire or pneumatic tubing connects to the damper actuator 			
The outside air thermostat(s) is functioning properly (e.g., in the right location, calibrated correctly)	×		
Proceed to Activities 13–16 if the damper seems to be operating properly. ACTIVITY 13: FREEZE STATS			
3s. Disconnected power to controls (for automatic reset only) to test continuity across terminals	۵		P
OR 3t. Confirmed (if applicable) that depressing the manual reset button (usually red) trips the freeze stat (clicking sound indicates freeze stat was tripped)	A		П
3u. Assessed the feasibility of replacing all manual reset freeze-stats with automatic reset freeze-stats	Л Я	_	
NOTE: HVAC systems with water coils need protection from the cold. The freezeclose the outdoor air damper and disconnect the supply air when tripped. The tylrange is 35°F to 42°F.			
ACTIVITY 14: MIXED AIR THERMOSTATS			
3v. Ensured that the mixed air stat for heating mode is set no higher than 65°F			X
Ensured that the mixed air stat for cooling mode is set no lower than the room thermostat setting	0	a	X
ACTIVITY 15: ECONOMIZERS			
3x. Confirmed proper economizer settings based on design specifications or local practices	. 🔾	0	A
NOTE: The dry-bulb is typically set at 65°F or lower.			
3y. Checked that sensor on the economizer is shielded from direct sunlight3z. Ensured that dampers operate properly (for outside air, return air,	. 🗖		×
exhaust/relief air, and recirculated air), per the design specifications	. a	a	X

NOTE: Economizers use varying amounts of cool outdoor air to assist with the cooling load of the room or rooms. There are two types of economizers, dry-bulb and enthalpy. Dry-bulb economizers vary the amount of outdoor air based on outdoor temperature, and enthalpy economizers vary the amount of outdoor air based on outdoor temperature and humidity level.

3. CONTROLS FOR OUTDOOR AIR SUPPLY (continued)

ACTIVITY 16: FANS

NOTE: If fan shuts off when the thermostat is satisfied, adjust control cycle as necessary to ensure sufficient outdoor air supply.

4. AIR DISTRIBUTION

ACTIVITY 17: AIR DISTRIBUTION

	Ensured that supply and return air pathways in the existing ventilation system perform as required		٥
40.	between rooms and corridors are functioning		
	TE: If ventilation system is closed or blocked to meet current fire codes, consult v fessional engineer for remedies.	vith d	ı
	Made sure every occupied space has supply of outdoor air (mechanical system or operable windows)		
4d.	Ensured that supply and return vents are open and unblocked		
	TE: If outlets have been blocked intentionally to correct drafts or discomfort, inve I correct the cause of the discomfort and reopen the vents.	estiga	ite
4e.	Modified the HVAC system to supply outside air to areas without an outdoor air supply	X	a
4f.	Modified existing HVAC systems to incorporate any room or zone layout and population changes		
4g.	Moved all barriers (for example, room dividers, large free-standing blackboards or displays, bookshelves) that could block movement of air in the room, especially those blocking air vents		
4h.	Ensured that unit ventilators are quiet enough to accommodate classroom activities		J
4i.	Ensured that classrooms are free of uncomfortable drafts produced by air from supply terminals	_ _	X

ACTIVITY 18: PRESSURIZATION IN BUILDINGS

NOTE: To prevent infiltration of outdoor pollutants, the ventilation system is designed to maintain positive pressurization in the building. Therefore, ensure that the system, including any exhaust fans, is operating on the "occupied" cycle when doing this activity.

4j. Ensured that air flows out of the building (using chemical smoke) through windows, doors, or other cracks and holes in exterior wall (for example, floor joints, pipe openings).....

5. EXHAUST SYSTEMS

ACTIVITY 19: EXHAUST FAN OPERATION

5a. Checked (using chemical smoke) that air flows into exhaust fan grille(s)

If fans are running but air is not flowing toward the exhaust intake, check for the following:

- Inoperable dampers
- · Obstructed, leaky, or disconnected ductwork
- · Undersized or improperly installed fan
- · Broken fan belt






5. EXHAUST SYSTEMS (continued)

ACTIVITY 20: EXHAUST AIRFLOW

NOTE: Prevent migration of indoor contaminants from areas such as bathroon and labs by keeping them under negative pressure (as compared to surrounding	ns, kit g spa	chens ces).	5,
5b. Checked (using chemical smoke) that air is drawn into the room from adjacent spaces	Yes	No	N/A
Stand outside the room with the door slightly open while checking airflow high the door opening (see "How to Measure Airflow").	and	low ir	1
5c. Ensured that air is flowing toward the exhaust intake	×(
ACTIVITY 21: EXHAUST DUCTWORK 5d. Checked that the exhaust ductwork downstream of the exhaust fan (which under positive pressure) is sealed and in good condition	is)		0
6. QUANTITY OF OUTDOOR AIR			
ACTIVITY 22: OUTDOOR AIR MEASUREMENTS AND CALCULATION	ONS		
NOTE: Refer to "How to Measure Airflow" for techniques.			
6a. Measured the quantity of outdoor air supplied (22a) to each ventilation unit6b. Calculated the number of occupants served (22b) by the ventilation unit	🗅	X	
under consideration	🖸	X	
6c. Divided outdoor air supply (22a) by the number of occupants (22b) to determine the existing quantity of outdoor air supply per person (22c)	🗅	×	
ACTIVITY 23: ACCEPTABLE LEVELS OF OUTDOOR AIR QUANTIT	IES		
6d. Compared the existing outdoor air per person (22c) to the recommended levels in Table 1	🗅	X	
6e. Corrected problems with ventilation units that supplied inadequate quantities of outdoor air to ensure that outdoor air quantities (22c) meet			

the recommended levels in Table 1

		al .
		2
		-



- 1. Read the IAQ
 Backgrounder and
 the Background
 Information for
 this checklist.
- 2. Keep the
 Background
 Information and
 make a copy of
 the checklist for
 future reference.
- 3. Complete the Checklist.
 - Check the "yes,"
 "no," or
 "not applicable"
 box beside each
 item. (A "no"
 response
 requires further
 attention.)
 - Make comments in the "Notes" section as necessary.
- Return the checklist portion of this document to the IAQ Coordinator.

Walkthrough Inspection Checklist

2024

1.	GROUND LEVEL	Voc	No	N/A
1a.	Ensured that ventilation units operate properly			
	Ensured there are no obstructions blocking air intakes		_	
	Checked for nests and droppings near outdoor air intakes			
1d.	Determined that dumpsters are located away from doors, windows, and outdoor air intakes			
le.	Checked potential sources of air contaminants near the building			
1.0	(chimneys, stacks, industrial plants, exhaust from nearby buildings)	4		
1f.	8			
_	Minimized pesticide application	لكر		
In.	Ensured that there is proper drainage away from the building (including roof downspouts)	الأر		
1 i.	Ensured that sprinklers spray away from the building and outdoor			
	air intakes	🗖		X
1j.	Ensured that walk-off mats are used at exterior entrances and that	√a)		
	they are cleaned regularly	¥	u	
2.	ROOF			
Wh	ile on the roof, consider inspecting the HVAC units (use the Ventilation Ch	ecklis	t).	
2a. 2b.	Ensured that the roof is in good condition	X X	0	
2c.	Checked that ventilation units operate properly (air flows in)	X		
2d.	Ensured that exhaust fans operate properly (air flows out)	و×		
2e.	Ensured that air intakes remain open, even at minimum setting	<u></u> 28		
2f.	Checked for nests and droppings near outdoor air intakes	X		
2g.	Ensured that air from plumbing stacks and exhaust outlets flows away from outdoor air intakes	<u>\</u>	0	
2	ATTIC			
ა .	ATTIC			
3a.	Checked for evidence of roof and plumbing leaks	X		
3b.	Checked for birds and animal nests	<u>×</u>		
4.	GENERAL CONSIDERATIONS			
4a.	Ensured that temperature and humidity are maintained within acceptable ranges	ν.		
4h	Ensured that no obstructions exist in supply and exhaust vents			_
	Checked for odors			
4d.	Checked for signs of mold and mildew growth	V	. 0	

4.	GENERAL CONSIDERATIONS (continued)	96	Nο	N/A
4e.	Checked for signs of water damage			
	Checked for evidence of pests and obvious food sources			
4g.	Noted and reviewed all concerns from school occupants	₹		
5 .	BATHROOMS AND GENERAL PLUMBING			
	Ensured that bathrooms and restrooms have operating exhaust fans	Š)		
	Water is poured down floor drains once per week (approx. 1 quart of water)	9		
	Water is poured into sinks at least once per week (about 2 cups of water) &			
	Toilets are flushed at least once per week	A(a
6.	MAINTENANCE SUPPLIES			
6a.	Ensured that chemicals are used only with adequate ventilation and when	a/		0
	building is unoccupied	X		
6b.	Ensured that vents in chemical and trash storage areas are operating	ת	П	П
60	Ensured that portable fuel containers are properly closed			
	Ensured that portable fuel containers are properly closed	7	_	_
oa.	been serviced and maintained according to manufacturers' guidelines	Ą	Q	
7.	COMBUSTION APPLIANCES			
7a	Checked for combustion gas and fuel odors	7		
	Ensured that combustion appliances have flues or exhaust hoods			_
	Checked for leaks, disconnections, and deterioration			_
	Ensured there is no soot on inside or outside of flue components		ā	ā
8.	OTHER			
8a.	Checked for peeling and flaking paint (if the building was built before			
	1980, this could be a lead hazard)			
8b.	Determined date of last radon test	4		



Food Service Checklist

Name: Ponna Plante/	Lory kneeland
School: East God	
Room or Area: All	Date Completed: 121512024
Signature: Derrappe	alo


Instructions

- 1. Read the IAQ
 Backgrounder and
 the Background
 Information for
 this checklist.
- 2. Keep the
 Background
 Information and
 make a copy of
 the checklist for
 future reference.
- 3. Complete the Checklist.
 - Check the "yes,"
 "no," or
 "not applicable"
 box beside each
 item. (A "no"
 response
 requires further
 attention.)
 - Make comments in the "Notes" section as necessary.
- Return the checklist portion of this document to the IAQ Coordinator.

1.	COOKING AREA - we do not provide a school		
1a.	Determined that local exhaust fans operate properly (note if fans are excessively noisy)	No	N/A
	Checked for odors near cooking, preparation, and eating areas		×
1c.	Ensured that exhaust fans are used whenever cooking, washing dishes,		4
1 d.	and cleaning		
	Verified that gas appliances are vented outdoors	ā	3
1 f.	Ensured there are no combustion gas or natural gas odors, leaks, back-		
1~	drafting, or headaches when gas appliances are used		Ø
	Checked for signs of microbiological growth in the kitchen, including		A
	the upper walls and ceiling (for example, mold, slime, and algae)		×
1 i.	Selected biocides registered by EPA (if required), followed the		
	manufacturer's directions for use, and carefully reviewed the method of application		54
1j.	Verified the kitchen is free of plumbing and ceiling leaks (signs include	_	
	stains, discoloration, and damp areas)		X
•	FOOD HANDLING AND GTODAGE		
2.	FOOD HANDLING AND STORAGE		
2a.	Checked food preparation, cooking, and storage areas for signs of insects and vermin (for example, feces or remains)		×
2b.	Stored leftovers in well-sealed containers with no traces of food on outside surfaces		×
2c.	Ensured that food preparation, cooking, and storage practices are sanitary \Box		
	Disposed of food scraps properly and removed crumbs		M
2e.	Cleaned counters with soap and water or a disinfectant (according to school policy)		×
2f.	Swept and wet mopped floors.	0	X
3.	WASTE MANAGEMENT		
3a.	Selected and placed waste in appropriate containers		
	Ensured that containers' lids are securely closed		
3c.	Separated food waste and food-contaminated items from other wastes,	П	
3d	if possible		
	Ensured that dumpsters are properly located (away from air intake	_	
	vents, operable windows, and food service doors in relation to	_	
	prevailing winds)		

4.	D	Εl	LI	VI	ΕI	RI	ES	

	\	/es	INO	IN/A
4a.	Instructed vendors to avoid idling their engines during deliveries	₽		
	Posted a sign prohibiting vehicles from idling their engines in	1		
	receiving areas	V		
4c.	Ensured that doors or air barriers are closed between receiving area	/\		
	and kitchen			038
		_		~





- 1. Read the IAQ

 Backgrounder and the Background Information for this checklist.
- 2. Keep the
 Background
 Information and
 make a copy of
 the checklist for
 future reference.
- 3. Complete the Checklist.
 - Check the "yes,"
 "no," or
 "not applicable"
 box beside each
 item. (A "no"
 response
 requires further
 attention.)
 - Make comments in the "Notes" section as necessary.
- Return the checklist portion of this document to the IAQ Coordinator.

Integrated Pest Management Checklist

Na	ame: Donne P Leate / Lory kneepand/ Ju	nt	hay	altho
Sc	hool: Eastford			_
Ro	pom or Area: de Date Completed: 121112	024	1	
Si	gnature: Denna P Recelo			
		1, 11	22.11	
	OFFICIAL POLICY STATEMENT	Yes	No	N/A
1a.	Developed or located the school's official policy statement for integrated pest management (IPM)	X		П
	post management (11 111)	· · · · · · · · · · · · · · · · · · ·	_	•
2.	DESIGNATING PEST MANAGEMENT ROLES			
	Assigned and trained a qualified person to be the pest manager			
	Involved decision makers in the IPM program	X		
20.	and asked them to keep their areas clean and free of clutter	x i		
2d.	Encouraged parents to learn about IPM practices and implement them	X		
2e.	at home Developed a program to educate and train all IPM participants			
2f.	Included language about IPM into contracts with pest management	25/25		
	professionals	🗅		×
3.	SETTING PEST MANAGEMENT OBJECTIVES			
3a.	Set appropriate pest management objectives for school buildings (such as			
	preventing pests from interfering with students' learning environment and preserving the integrity of the building structure)	··· 😾	П	
3b.		X	_	_
	providing safe playing areas and the best athletic surfaces possible)			
4.	INSPECTING, IDENTIFYING, AND MONITORING			
4a.	Inspected all buildings and grounds for pest evidence, entry points,			
41	food, water, and harborage sites	X		_
4b. 4c.	Identified potential pest habitats in buildings and grounds Pinpointed the source of any current pest problems			0
4d.	Monitored to determine the extent of pest problems and to estimate pest	X	_	
10	populations Developed plans to modify habitat (for example, exclusion, repair, and	₩		
40.	sanitation efforts) to prevent or resolve any pest problems	🗣		
4f.	Established a monitoring program that consists of routine inspections to estimate pest population levels and identify evidence of pests and	/		

potential habitat

5. SETTING ACTION THRESHOLDS Yes No N/A 5a. Evaluated all available data obtained through inspecting, identifying, 5b. Determined how many pests the school buildings, grounds, and 5c. Set action thresholds 6. PREVENTIVE STRATEGIES INDOOR SITES 6a. Implemented appropriate strategies to prevent pests from inhabiting the following areas: • Entryways • Gymnasiums • Locker rooms • Offices • Staff lounges • Bathrooms • Rooms with extensive plumbing **OUTDOOR SITES** 6b. Implemented appropriate strategies to prevent pests from inhabiting the following areas: • Lawns and athletic fields...... • Teaching gardens or greenhouses • Loading docks 7. PESTICIDE USE AND STORAGE 7a. Explored alternative pest management methods before concluding that 7b. Ensured that pest management professionals integrate IPM into their pest management methods 7c. Identified the least toxic, target-specific chemical (or pesticide formulation) that is the most effective to address the pest problem, preferably as baitsand granules 7d. Reviewed and followed all label instructions on pesticides and learned 7e. Used spot-treatment (or bait, crack, and crevice applications) to apply pesticides whenever possible and only treated the obviously infested plants in the area 7g. Placed all pesticides in tamper-resistant bait boxes or locations that are





7. PESTICIDE USE AND STORAGE (cont.)

7h.	Locked or fastened lids of all bait boxes and placed bait away from the runway of the box	Yes	No	N/A
7i.	Applied pesticides when occupants were not present or in areas where they would not be exposed to the chemicals	Þ		
7j.		×	0	
7k.	Ensured that parents are notified of upcoming pesticide applications through letters	23		
71.	Kept copies of current pesticide labels and information on pesticides easily accessible	A		
7m.	Stored pesticides off site or in areas that are locked and accessible only to designated personnel) Jr		
7n.	Ensured that storage areas are adequately ventilated and are located away from areas prone to flooding or where spills or leaks may contaminate	,	•	J
_		A		
	Ensured that flammable liquids are stored away from ignition sources Ensured that pesticides are stored in their original containers and all lids	×		
	are securely fastened	×		
/q.	Ensured that air in the storage space cannot mix with the air in the central ventilation system	×		
8.	EVALUATING RESULTS AND RECORD KEEPING			
8a.	Ensured that accurate, up-to-date records of IPM practices and a pest management log for each property are kept	M		
8b.	Ensured that pesticide records necessary to meet all state, local, and school	/ .	_	0
8c.	board requirements are maintained Ensured that each log book contains the following items:	K	П	ш
	Copy of the pest management plan	M		
	• Service schedules for maintenance of buildings and grounds	Q		
	Current EPA-registered labels			
	• Current Material Safety Data Sheets (MSDS) for each pesticide project			
	Pest surveillance data sheets			
	• Diagram noting the location of pest activity, traps, and bait stations	x		



- 1. Read the IAQ
 Backgrounder and
 the Background
 Information for
 this checklist.
- 2. Keep the
 Background
 Information and
 make a copy of
 the checklist for
 future reference.
- 3. Complete the Checklist.
 - Check the "yes,"
 "no," or
 "not applicable"
 box beside each
 item. (A "no"
 response
 requires further
 attention.)
 - Make comments in the "Notes" section as necessary.
- 4. Return the checklist portion of this document to the IAQ Coordinator.

Waste Management Checklist

Name: Donna Pleato	/Lary Exceland
School: Fastfard	
Room or Area:	Date Completed: 1204/2024
Signature: LONG PRANCE)

1.	WASTE MANAGEMENT			
		Yes	No	N/A
la.	Ensured that waste containers are appropriate for use (for example, food waste containers should have lids) Ensured that waste containers are lined	/		
1 b.	Ensured that waste containers are lined	.Xi		
	Ensured that waste from art, science, vocational classes, etc., are	•		
	handled separately	. 🛚		
1d.	Labeled recycling bins clearly			
	Ensured number of bins and dumpsters is adequate			
1 f.	Ensured appropriate location of dumpsters (i.e., away from air intakes, doors, and operable windows in relation to prevailing winds)	B		
1g.	Ensured waste containers are emptied regularly			
	Ensured appropriate waste removal schedule			
1i.	Ensured waste is stored in a well-ventilated room	K		
1j.	Ensured any exhaust fans in the room are operating properly	. 🗷		
1k.	Checked waste storage areas for odors, contaminants, or signs of vermin	. Ø		